



CERTIFICATE OF COMPLIANCE

ASSOCIATED AIR-PAK INDUSTRIES SDN BHD

Cleanbooth
ISO Class 4 & 5 (Class 10 & 100)

Test Condition: At Rest

As per requirement of ISO 14644-1:2015 the designated area listed have met the respective acceptance criteria. Testing was performed as outlined in the above standard and the results are attested to it in the Report No. 378/CR/23



Son Oat

Date of Certification: 21st December 2023 Due Date: 21st December 2024 Tan Chee Kian
CPT Certified Professional

NEXTECH SDN. BHD.

19, Jalan Bukit Badung 26/4, HICOM Industrial Estate 40000 Shah Alam, Selangor Darul Ehsan, Malaysia. Tel: 03-51923833 Fax: 03-51922088





CERTIFICATE OF COMPLIANCE

ASSOCIATED AIR-PAK INDUSTRIES SDN BHD

Cutting & Inner Packing Area ISO Class 7 (Class 10,000)

Test Condition: At Rest

As per requirement of ISO 14644-1:2015 the designated area listed have met the respective acceptance criteria. Testing was performed as outlined in the above standard and the results are attested to it in the Report No. 378/CR/23



on De F

Date of Certification: 21st December 2023 Due Date: 21st December 2024 Tan Chee Kian
CPT Certified Professional

NEXTECH SDN. BHD.

19, Jalan Bukit Badung 26/4, HICOM Industrial Estate 40000 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-51923833 Fax: 03-51922088





CERTIFICATE OF COMPLIANCE

ASSOCIATED AIR-PAK INDUSTRIES SDN BHD

Change Room
ISO Class 8 (Class 100,000)

Test Condition: At Rest

As per requirement of ISO 14644-1:2015 the designated area listed have met the respective acceptance criteria. Testing was performed as outlined in the above standard and the results are attested to it in the Report No. 378/CR/23



Som Book

Date of Certification: 21st December 2023 Due Date: 21st December 2024 Tan Chee Kian
CPT Certified Professional

NEXTECH SDN. BHD.

19, Jalan Bukit Badung 26/4, HICOM Industrial Estate 40000 Shah Alam, Selangor Darul Ehsan, Malaysia. Tel: 03-51923833 Fax: 03-51922088





CLEANROOM PERFORMANCE TESTING AND CERTIFICATION REPORT

The data presented in this report is an exact record of the rooms and room system performance on the day of the test. They are obtained in accordance with the ISO 14644-1:2015 the relevant sections of the Institute Of Environmental Science Recommended Practice, IES-RP-CC006.3, and the National Environmental Balancing Bureau (NEBB) Procedural Standards for Certified Testing of Cleanroom 2009-3rd Edition.

The results and information given are certified to be correct and complete, to the extent possible by the equipment / instrumentation and procedures used.

Submitted & Certified By: **NEXTECH SDN. BHD.**

Tan Chee Kian NEBB Certified Professional Firm Certification No. 3144

